Lumina	ire Sched	lule (note fixtu	re catalog	e numbers are no	ot complete)
Type	Qty	Lum.	LLF	Lum. Watts	Description
		Lumens			·
SA	1	8085	0.900	83.6	VP-1-36L-85-3K7-4W
SB	1	9026	0.900	83.6	VP-1-36L-85-3K7-4F
SC	2	8831	0.900	83.6	VP-1-36L-85-3K7-5QW
W1	5	3538	0.900	28	RWL1-48L-25-3K7-4W-U
W2	1	3587	0.900	28	RWL1-48L-25-3K7-3-U

PLAN VIEW

Calculation Su	mmary				
Label	Avg	Max	Min	Avg/Min	Max/Min
SITE	0.29	3.5	0.0	N.A.	N.A.
PARKING	1.49	2.4	0.6	2.48	4.00

NOTES: 1) EXACT MOUNTING DETAILS TO BE DETERMINED AT JOBSITE BY OTHERS.

2) CALCULATIONS MAY or MAY NOT SHOW THE EFFECT OF SHADOWING CAUSED BY BUILDINGS AND OBJECTS WITHIN THE CALCULATED SPACE OR IN THE SITE AREA.

3) READINGS SHOWN ARE INITIAL HORIZONTAL FOOTCANDLES ON A FLAT SITE WITHOUT REFLECTIONS OR OBSTRUCTIONS UNLESS OTHERWISE INDICATED.

SWANEY LIGHTING ASSOCIATES AND STANDARD ASSUMPTIONS OF THE SPACE AND/OR SITE. 5) CONFORMANCE TO CODES AND OTHER LOCAL REQUIREMENTS AS DETERMINED BY THE AHJ ARE THE RESPONSIBILITY OF THE OWNER AND/OR THE OWNER'S REPRESENTATIVE. 6) THIS LAYOUT DRAWING MUST BE COORDINATED WITH THE SITE LOCATION FOR CORRECT FIXTURE ORIENTATION.

LAYOUT

7) DOCUMENTS PRINTED OR PLOTTED FROM ELECTRONIC FILES MAY APPEAR AT OTHER THAN THE DESIRED OR ASSUMED GRAPHIC SCALES.

