### **Sheri Gagnon Memorial Park Tennis** Raymond, ME

### **Lighting System**

	Pole/Fixture Summary								
ı	Pole ID	Pole Height	Mtg Height	Fixture Qty	Luminaire Type	Load	Circuit		
	T1-T4	60'	60'	2	TLC-LED-550	1.08 kW	Α		
ı	4			8		4.32 kW			

Circuit Summary						
Circuit	Description	Load	Fixture Qty			
Α	Tennis	4.32 kW	8			

Fixture Type Summary							
Туре	Source	Wattage	Lumens	L90	L80	L70	Quantity
TLC-LED-550	LED 5700K - 75 CRI	540W	67,000	>120,000	>120,000	>120,000	8

Single Luminaire Amperage Draw Chart								
Driver Specifications Line Amperage Per Luminaire								
(.90 min power factor)		(max draw)						
Single Phase Voltage	208	220	240	277	347	380	480	
Siligle Filase Voltage	(60)	(60)	(60)	(60)	(60)	(60)	(60)	
TLC-LED-550	3.2	3.0	2.8	2.4	1.9	1.8	1.4	

### **Light Level Summary**

Calculation Grid Summary								
Grid Name	Calculation Metric		Illumination					Fixture
Gila Name	Calculation Wethic	Ave	Min	Max	Max/Min	Ave/Min	Circuits	Qty
Pickleball	Horizontal Illuminance	20.68	12	28	2.25	1.66	Α	8
Property Line Spill	Horizontal	0.00	0	0	-	-	Α	8
Property Line Spill	Max Vertical Illuminance Metric	0.00	0	0	-	-	Α	8
Property Line Spill (Cd)	Max Candela (by Fixture)	86.40	0	1837	72750.73	3421.00	Α	8
Tennis	Horizontal Illuminance	21.57	17	26	1.51	1.24	Α	8
Zero Grid	Horizontal Illuminance	4.88	0	28	151961.91	26704.28	Α	8

### From Hometown to Professional












Equipment List For Areas Shown										
Pole					Luminaires					
QTY	LOCATION	SIZE	GRADE ELEVATION	ABOVE GRADE LEVEL	LUMINAIRE TYPE	QTY/POLE	THIS GRID	OTHER GRIDS		
4	T1-T4	60'	-	60'	TLC-LED-550	2	2	0		
4	Totals						8	0		

<sup>\*</sup>Above Grade level relative to the field





Pole location(s) ⊕ dimensions are relative to 0,0 reference point(s) ⊠

### **Sheri Gagnon Memorial Park Tennis**

### Raymond, ME

<b>Grid Summary</b>	
Name	Tennis
Size	2 Court - 20' Spacing
Spacing	20.0' x 20.0'
Height	3.0' above grade

Illumination Summary				
	MAINTAINED HORIZONTAL FOOTCANDLES			
	Entire Grid			
Guaranteed Average	20			
Scan Average	21.57			
Maximum	26			
Minimum	17			
Avg/Min	1.24			
Guaranteed Max/Min	3			
Max/Min	1.51			
UG (adjacent pts)	0.00			
CU	0.51			
No. of Points	30			
LUMINAIRE INFORMATION				
Applied Circuits	A			
No. of Luminaires	8			
Total Load	4.32 kW			

**Guaranteed Performance:** The ILLUMINATION described above is guaranteed per your Musco Warranty document and includes a 0.95 dirt depreciation factor.

**Field Measurements:** Individual field measurements may vary from computer-calculated predictions and should be taken in accordance with IESNA RP-6-15.


Electrical System Requirements: Refer to Amperage Draw Chart and/or the "Musco Control System Summary" for electrical sizing.

Installation Requirements: Results assume ± 3% nominal voltage at line side of the driver and structures located within 3 feet (1m) of design locations.



Equi	Equipment List For Areas Shown									
Pole					Luminaires					
QTY	LOCATION	SIZE	GRADE ELEVATION	ABOVE GRADE LEVEL	LUMINAIRE TYPE	QTY/POLE	THIS GRID	OTHER GRIDS		
4	T1-T4	60'	-	60'	TLC-LED-550	2	2	0		
4	Totals 8 8 0						0			

<sup>\*</sup>Above Grade level relative to the field



### **Sheri Gagnon Memorial Park Tennis**

### Raymond, ME



Illumination Summary					
	MAINTAINED HORIZONTAL FOOTCANDLES				
	Entire Grid				
Guaranteed Average	20				
Scan Average	20.68				
Maximum	28				
Minimum	12				
Avg/Min	1.66				
Guaranteed Max/Min	3				
Max/Min	2.25				
UG (adjacent pts)	1.43				
CU	0.19				
No. of Points	48				
LUMINAIRE INFORMATION					
Applied Circuits	Α				
No. of Luminaires	8				
Total Load	4.32 kW				

**Guaranteed Performance:** The ILLUMINATION described above is guaranteed per your Musco Warranty document and includes a 0.95 dirt depreciation factor.

Field Measurements: Individual field measurements may vary from computer-calculated predictions and should be taken in accordance with IESNA RP-6-15.

Electrical System Requirements: Refer to Amperage Draw Chart and/or the "Musco Control System Summary" for electrical sizing.

Installation Requirements: Results assume ± 3% nominal voltage at line side of the driver and structures located within 3 feet (1m) of design locations.





**p.0 p.0 p.0 p.1 p.1 p.1 p.1 p.3 p.1 p.1 p.3 p.1 p.5 p.3 p.1 p.7 p.7 p.8 p.8 p.8 p.8 p.8 p.8 p.9 p.9** 0.0 0.0 0.1 0.1 0.2 0.2 0.7 2.3 4.0 6.1 7.4 7.5-8-8-41-142-542-142-142-142-142-14-29-1-6-7-6-3-6-2-5-5-3-9-2-5 1.1 0.3 0.1 0.1 0.0 0.0 0.0 0.0 0.0 7<sub>-</sub>13.5<sub>-</sub>14.1<sub>-</sub>14<mark>-3</mark>-15.8<sub>-</sub>17.2<sub>-</sub>17.7<sub>-</sub>16.9<sub>-</sub>16.5<sub>-</sub>17.1<sub>-</sub>17.1<sub>-</sub>15.7<sub>-</sub>13.0<sub>-</sub>11.0<sub>-</sub>11.5<sub>-</sub>10 9,18.2,18.8,19<mark>,0</mark>,19.2,21.3,21.2,19.0,18.9,20.7,21.4,20.3,17.5,15.3,15.8,1 9,20.9,23.1,23 . 22.8 24.1 23.4 19.8 19 2 21.3 23 4 23.0 20.5 18.3 18.5 1 6 14.8 9.6 5.8 3.2 1.6 p.6 p.2 p.1 p.1 p.0 26.2 24.9 22.1 19.2 18.7 22.2 25.2 25.9 24.6 20.6 19.9 17 1,21.8,23.4,25<mark>.2</mark> 0.7 1.6 3.4 6.6 10.2 14318.8 24.3 27 6 27.1 24.7 22.1 19.5 18.3 20.3 22 8 25.2 25.5 24.2 20.7 1 5 26.9 24.5 22.0 19.5 18.2 29 **2** 23.0 25.3 25.3 23.9 20.1. 0,20.4,23.6,26<mark>.7</mark> 27.8 25.6 21.9 19.0 18.9 21.4 24.5 26.9 26.7 22.3 18.7 16 . 26.7 24.7 22.1.19.4.18.6 22.1 25.7 26.2 24.7 21.3 **2**0.1.1<mark>8</mark> 6,22.1,23.1,23<mark>.3</mark> 23.3<mark>23.422.619.318.821.423.</mark>723.321.018.7<mark>1</mark>9.0<del>18</del> p.2 p.4 1.2 3.8 6.9 **p.0 p.0 p.0 p.1 p.1 p.1 p.3 p.2 p.3 p.2 p.3 p.4 p.5 p.6 p.7 p.7** 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0



Pole location(s) ⊕ dimensions are relative to 0,0 reference point(s) ⊠

### **Sheri Gagnon Memorial Park Tennis**

#### Raymond, ME

### Grid Summary

Name Zero Grid Spacing 10.0' x 10.0' Height 3.0' above grade

# MAINTAINED HORIZONTAL FOOTCANDLES Entire Grid Scan Average 4.88 Maximum 0 Avg/Min 26704.28 Max/Min 151961.91 UG (adjacent pts) CU No. of Points LUMINAIRE INFORMATION Applied Circuits No. of Luminaires Total Load 4.32 kW


**Guaranteed Performance:** The ILLUMINATION described above is guaranteed per your Musco Warranty document and includes a 0.95 dirt depreciation factor.

**Field Measurements:** Individual field measurements may vary from computer-calculated predictions and should be taken in accordance with IESNA RP-6-15.

**Electrical System Requirements:** Refer to Amperage Draw Chart and/or the "Musco Control System Summary" for electrical sizing.

Installation Requirements: Results assume ± 3% nominal voltage at line side of the driver and structures located within 3 feet (1m) of design locations.





SCALE IN FEET 1 : 100

0' 100' 200'

ENGINEERED DESIGN By: T.Lanphier • File #225091B • 11-Jun-24

Pole location(s)  $\oplus$  dimensions are relative to 0,0 reference point(s)  $\boxtimes$ 

### **Sheri Gagnon Memorial Park Tennis**

### Raymond, ME

### Grid Summary Name Property Line Spill Spacing 30.0' x 10.0' Height 3.0' above grade

Illumination Summary					
	MAINTAINED HORIZONTAL FOOTCANDLES				
	Entire Grid				
Scan Average	0.00				
Maximum	0				
Minimum	0				
Avg/Min	-				
Max/Min	-				
UG (adjacent pts)	0.00				
CU	0.00				
No. of Points	67				
LUMINAIRE INFORMATION					
Applied Circuits	A				
No. of Luminaires	8				
Total Load	4.32 kW				


**Guaranteed Performance:** The ILLUMINATION described above is guaranteed per your Musco Warranty document and includes a 0.95 dirt depreciation factor.

**Field Measurements:** Individual field measurements may vary from computer-calculated predictions and should be taken in accordance with IESNA RP-6-15.

Electrical System Requirements: Refer to Amperage Draw Chart and/or the "Musco Control System Summary" for electrical sizing.

Installation Requirements: Results assume ± 3% nominal voltage at line side of the driver and structures located within 3 feet (1m) of design locations.





SCALE IN FEET 1 : 100

0' 100' 200'

ENGINEERED DESIGN By: T.Lanphier • File #225091B • 11-Jun-24

Pole location(s)  $\oplus$  dimensions are relative to 0,0 reference point(s)  $\boxtimes$ 

### **Sheri Gagnon Memorial Park Tennis**

### Raymond, ME

## Grid Summary Name Property Line Spill Spacing 30.0' x 10.0' Height 3.0' above grade

Illumination Summary					
	MAINTAINED MAX VERTICAL FOOTCANDLES				
	Entire Grid				
Scan Average	0.00				
Maximum	0				
Minimum	0				
Avg/Min	-				
Max/Min	-				
UG (adjacent pts)	0.00				
CU	0.00				
No. of Points	67				
LUMINAIRE INFORMATION					
Applied Circuits	A				
No. of Luminaires	8				
Total Load	4.32 kW				


**Guaranteed Performance:** The ILLUMINATION described above is guaranteed per your Musco Warranty document and includes a 0.95 dirt depreciation factor.

**Field Measurements:** Individual field measurements may vary from computer-calculated predictions and should be taken in accordance with IESNA RP-6-15.

Electrical System Requirements: Refer to Amperage Draw Chart and/or the "Musco Control System Summary" for electrical sizing.

Installation Requirements: Results assume ± 3% nominal voltage at line side of the driver and structures located within 3 feet (1m) of design locations.





SCALE IN FEET 1 : 100

0' 100' 200'

ENGINEERED DESIGN By: T.Lanphier • File #225091B • 11-Jun-24

Pole location(s)  $\oplus$  dimensions are relative to 0,0 reference point(s)  $\boxtimes$ 

### **Sheri Gagnon Memorial Park Tennis**

### Raymond, ME

### Grid Summary

Name Property Line Spill (Cd) Spacing 30.0' x 10.0' Height 5.0' above grade

Illumination Summary						
MAINTAINED MAX CANDELA (PER FIXTU						
	Entire Grid					
Scan Average	86.40					
Maximum	1837					
Minimum	0					
Avg/Min	3421.00					
Max/Min	72750.73					
UG (adjacent pts)	0.00					
CU	0.00					
No. of Points	67					
LUMINAIRE INFORMATION						
Applied Circuits	A					
No. of Luminaires	8					
Total Load	4.32 kW					


**Guaranteed Performance:** The ILLUMINATION described above is guaranteed per your Musco Warranty document and includes a 0.95 dirt depreciation factor.

**Field Measurements:** Individual field measurements may vary from computer-calculated predictions and should be taken in accordance with IESNA RP-6-15.

**Electrical System Requirements:** Refer to Amperage Draw Chart and/or the "Musco Control System Summary" for electrical sizing.

Installation Requirements: Results assume ± 3% nominal voltage at line side of the driver and structures located within 3 feet (1m) of design locations.





### SCALE IN FEET 1:80 0' 80' 160' ENGINEERED DESIGN By: T.Lanphier • File #225091B • 11-Jun-24

Pole location(s)  $\oplus$  dimensions are relative to 0,0 reference point(s)

### **Sheri Gagnon Memorial Park Tennis**

### Raymond, ME

### **Equipment Layout**

INCLUDES:
· Pickleball
· Tennis

**Electrical System Requirements:** Refer to Amperage Draw Chart and/or the "Musco Control System Summary" for electrical sizing.

Installation Requirements: Results assume ± 3% nominal voltage at line side of the driver and structures located within 3 feet (1m) of design locations.

Eq	Equipment List For Areas Shown										
Pole			Luminaires								
QTY	LOCATION	SIZE	GRADE ELEVATION	ABOVE GRADE LEVEL	LUMINAIRE TYPE	QTY/POLE					
4	T1-T4	60'	-	60'	60' TLC-LED-550						
4	Totals										

Single Luminaire Amperage Draw Chart										
Driver Specifications	Line Amperage Per Luminaire									
(.90 min power factor)	(max draw)									
Single Phase Voltage	208	220	240	277	347	380	480			
	(60)	(60)	(60)	(60)	(60)	(60)	(60)			
TLC-LED-550	3.2	3.0	2.8	2.4	1.9	1.8	1.4			

