Bruce,
I inspected the A La Mexicana for Life Safety today for the Liquor Lic.Application today.
They made a couple of corrections during the inspection and 1 emergency light needs a replacement battery
which they are in the process of correcting.
One other note is that their fire extinguishers need to be tagged in January as well as the Ancell System in the Kitchen.

I noted no other violations.

Thanks, Chris

--
Christopher Hanson
Code Enforcement Office
Town of Raymond
401 Webbs Mills Road
(207)655-4742 ext 42