On 4/8/2014 11:36 AM, Dave Mains wrote:
> Louise,
>
> Attached is my inspection report and memo to the Selectman for the
> Fisherman's Catch liquor license. Bill has a couple of maintenance
> items to correct and will be installing address numbers and a key
> box. None of these present a life safety problem for the fire
> department.
>
> Please let me know if there are any questions.
>

--
Louise H. Lester, Town Clerk
Town of Raymond
401 Webbs Mills Road
Raymond, Maine 04071
207-655-4742 ext. 121
louise.lester@raymondmaine.org

--

Bruce Tupper
Chief

Town of RAYMOND
Home of the Landlocked Salmon
INCORPORATED 1803

Cathy Gosselin
Deputy Chief

FIRE/RESCUE

1443Roosevelt Trail
Raymond, Maine 04071

Emergency 9-1-1 *Chief's Office 655-1187* *Dispatch 655-7851*

Date: April 8, 2014

To: Raymond Board of Selectmen

From: David Mains, Raymond Fire Inspector

RE: Fisherman's Catch Liquor License Life Safety Inspection

I have received a copy of the State Liquor License application for Mr. Coppersmith and the Fisherman's Catch. On April 8, 2014 the Raymond Fire Department performed a life safety inspection of the Fisherman's Catch at 1270 Roosevelt Trail. The attached report identifies items that the Owner, Mr. Coppersmith will be addressing. The results of our inspection are that the property meets the meets the requirements of NFPA 101 Life Safety Code at this time.

Mr. Coppersmith will be installing address numbers and a key box as required to comply with Town of Raymond Ordinances. These items are not creating a life safety danger at the occupancy currently.

If there are any questions, please contact me.

Respectfully,

David Mains
Raymond Fire Inspector

Raymond Fire & Rescue

Occupancy: **Fishermen's Catch Restaurant**
Address: **1270 Roosevelt TRL**
Raymond ME 04071

Inspection Type: **Annual**
Inspection Date: **4/8/2014** By: Mains, David (MAINSD)
Time In: **09:09** Time Out: **09:31**
Authorized Date: **04/08/2014** By: Mains, David (MAINSD)

Form: Annual 14-0408

Inspection Description:

Annual Inspection Form

Inspection Topics:

General

Address numbers 3 inches high visible from street.

Raymond Addressing Ordinance Section xxx Numbers must be a contrasting color to the background. Address numbers are critical to emergency personnel in finding people who may need assistance or aid in an emergency.

Status: FAIL
Notes: Install 3 inch letters either over front door or on sign

Is a Knox Box installed. Are the keys current?

All properties protected by a Fire Alarm System and or a Fire Suppression System shall have a Knox Box with current keys to the property. Raymond Fire Protection Ordinance Article 5 Section 1

Status: FAIL
Notes: Owner shall install a Knox box.

Housekeeping

Clean grease filters and hood/duct system over cooking equipment.

Regular cleaning of the hood, duct, and filters will eliminate flammable grease build-up and provide proper ventilation of head through the exhaust outlet.

Status: Routine Maintenance
Notes: Update hood inspection sticker

Fire Alarm

Has a current fire alarm test report on file with the Raymond Fire Department.

Raymond Fire Protection Ordinance (Article 5 Section 1) requires an annual fire alarm test report be filed with the Office of the Fire Inspector before January 1 each year.

Status: Information
Notes: Annual registration required

Electrical Systems

Are electrical systems properly installed?

Description

Status: Routine Maintenance

Notes: Organize electrical cords and secure. Do not drape device cords above floor.

Each outlet box shall have a cover faceplate or fixture canopy.

Covers protect people from being shocked by exposed wires, prevent spread of electrical current, and heat and flame during short circuits.

Status: Routine Maintenance

Notes: Remove outlet or replace cover on exterior outlet on east side

Additional Time Spent on Inspection:

Category	Start Date / Time	End Date / Time

Notes: No Additional time recorded

Total Additional Time: 0 minutes

Inspection Time: 22 minutes

Total Time: 22 minutes

Summary:

Overall Result: Correction Notice Issued

Items found in an inspection require correction by the Owner or Occupant. These items are required to be corrected for the Occupancy to comply with the Raymond Fire Protection Ordinance or State Fire Code. The Owner is required to notify the Raymond Fire Department when ALL items listed have been corrected.

Inspector Notes:

Owner agreed to correct all items indicated and will pick up a knox box authorization and annual fire alarm registration form at the Public Safety Building.

Closing Notes:

This fire prevention inspection has been made by the Raymond Fire Department for the purpose of promoting fire safety and to assist the Owner or Operator of the Occupancy in identifying conditions that require correction. Items listed in this inspection report must be corrected before the Occupancy will deemed in compliance with the Raymond Fire Protection Ordinance.